

# Pre Rinse Wall Exposed Mixer Assembly with Pot Filler

The Enware Ultra Rinse range of Food Service Pre-Rinse assemblies are designed for use in Commercial Kitchens and Food Preparation areas.

A wide range of products to suit Wall and Bench mounting are available with mixers, pot fillers and various formats to suit different plumbing set-outs.

Heavy duty fixings and chrome plated finishes with anti-vandal fittings ensure easy cleaning for improved hygiene, and long lasting service for critical areas in the kitchen.

Adjustable sets for easy retro-fit and special shortened assemblies ensure there is a solution for all new and existing kitchens.

Service parts such as hoses, trigger sprays, spindles and handles are available to ensure downtime does not interrupt the work flow of a busy kitchen.



## PRODUCT CODE

FWS131

Pre Rinse Wall Exposed Mixer Assembly with Pot Filler

## KEY FEATURES

- Separate exposed hot and cold taps to provide either hot, cold water or mixed water
- Dual check valves for backflow protection
- Spring return allows the spray and hose to be pulled into the spraying position and to retract back from the washing area when released
- Pex hose with smooth outer covering and braided inner has in-built swivels to ensure ease of use and to assist to prevent user fatigue
- Quarter-turn, contra-rotating easy to clean 80mm lever handles
- Heavy duty Jumper Valve 1/4 Turn spindles, can be serviced
- Clear identification on all lever handles with blue, yellow, red or grey coloured indicator collars
- Includes Pot Filler
- Attractive, lead free brass chrome body
- Modular design allows tailoring for individual needs
- Also available with adjustable inlet centres- FWS131ADJ



Due to ongoing Research and Development, specifications may change without notice.

Component specifications may change on some export models.

Refer to warranty statement for warranty details - [www.enware.com.au/warranty](http://www.enware.com.au/warranty).

Products are to be installed in accordance with the Plumbing Code of Australia and AS/NZS3500.

Reference should also be made to the Australasian Health Facility Guidelines (AHFG), ABCB and Local Government regulations when considering the choice of, and the installation of these products.

